

VILLAGE OF MOREAUVILLE WATER SYSTEM

Public Water Supply ID: LA1009012

Consumer Confidence Report

2025 CCR

**Additional Information and Electronic Copies can be found at
www.ldh.la.gov/ccr**

What you need to do:

Review base report (numbered pages) for errors. If you are a surface water system, you must insert the turbidity data.

Distribute completed report to your customers as outlined on the CCR Certification of Distribution Form no later than June 30, 2026.

A completed CCR Certification of Distribution Form including a copy of the final CCR report shall be submitted to the State at the address provided on the form no later than September 30, 2026.

If submitting CCR Electronically by posting on a website, be aware of LAC 51:XII.403.C – Community water systems shall include their final letter grade and score in their annual Consumer Confidence Report (a.k.a. Annual Water Quality Report) that is posted on the water system website. A statement like below must be added to the CCR notifying consumers of the water system grade.

Our water system grade is a “fill in grade here”. Our water system report card can be found at “insert water system website link”.

UCMR5-Water systems are required to distribute results for the unregulated contaminant monitoring rule (UCMR). If you have collected samples and received results, you may insert that data into the CCR to satisfy the notification requirement. The average of all results and the range of results at with the contaminant was detected.

Notes:

This page is not part of your CCR; it is only the instruction page. The pages that are numbered in the upper right hand corner are the report pages.

The Water We Drink

VILLAGE OF MOREAUVILLE WATER SYSTEM

Public Water Supply ID: LA1009012

We are pleased to present to you the Annual Water Quality Report for the year 2025. This report is designed to inform you about the quality of your water and services we deliver to you every day (Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien). Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

Our water source(s) are listed below:

Source Name	Source Water Type
BUYS FROM LA1009021 AVOYELLES WATER COMM	Ground water
Z WELL 1 STAND BY PLUGGED	Ground water
Z WELL 2 PLUGGED	Ground water
Z WELL 3 MAIN PLUGGED	Ground water

Our water system also purchases water as listed below:

Buyer Name	Seller Name
LA1009012 - VILLAGE OF MOREAUVILLE WATER SYSTEM	AVOYELLES WATER COMMISSION

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

Microbial Contaminants - such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic Contaminants - such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and Herbicides - which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

Organic Chemical Contaminants - including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

Radioactive Contaminants - which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health. We want our valued customers to be informed about their water utility. If you have any questions about this report, want to attend any scheduled meetings, or simply

want to learn more about your drinking water, please contact BERYL HOLMES at 318-985-2338.

There is no safe level of lead in drinking water. Exposure to lead in drinking water can cause serious health effects in all age groups, especially pregnant people, infants (both formula-fed and breastfed), and young children. Some of the health effects to infants and children include decreases in IQ and attention span. Lead exposure can also result in new or worsened learning and behavior problems. The children of persons who are exposed to lead before or during pregnancy may be at increased risk of these harmful health effects. Adults have increased risks of heart disease, high blood pressure, kidney or nervous system problems. Contact your health care provider for more information about your risks.

The Louisiana Department of Health and Hospitals - Office of Public Health routinely monitors for constituents in your drinking water according to Federal and State laws. The tables that follow show the results of our monitoring during the period of January 1st to December 31st, 2025. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk.

In the tables below, you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms, we've provided the following definitions:

Parts per million (ppm) or Milligrams per liter (mg/L) – one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter (ug/L) – one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/L) – picocuries per liter is a measure of the radioactivity in water.

Treatment Technique (TT) – an enforceable procedure or level of technological performance which public water systems must follow to ensure control of a contaminant.

Action level (AL) – the concentration of a contaminant that, if exceeded, triggers treatment or other requirements that a water system must follow.

Maximum contaminant level (MCL) – the “Maximum Allowed” MCL is the highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLG's as feasible using the best available treatment technology.

Maximum contaminant level goal (MCLG) – the “Goal” is the level of a contaminant in drinking water below which there is no known or expected risk to human health. MCLG's allow for a margin of safety.

Maximum residual disinfectant level (MRDL) – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum residual disinfectant level goal (MRDLG) – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Level 1 assessment – A study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment – A very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

During the period covered by this report we had the below noted violations.

Compliance Period	Analyte	Type
7/1/2025 - 1/23/2026	CONSUMER CONFIDENCE RULE	CCR REPORT

Our water system tested a minimum of 2 sample(s) per month in accordance with the Total Coliform Rule for microbiological contaminants. With the microbiological samples collected, the water system collects disinfectant residuals to ensure control of microbial growth.

Disinfectant	Date	HighestRAA	Unit	Range	MRDL	MRDLG	Typical Source
CHLORINE	2025	1.2	ppm	0.71 - 1.45	4	4	Water additive used to control microbes

In the tables below, we have shown the regulated contaminants that were detected. Chemical Sampling of our drinking water may not be required on an annual basis; therefore, information provided in this table refers back to the latest year of chemical sampling results.

Regulated Contaminants	Collection Date	Water System	Highest Value	Range	Unit	MCL	MCLG	Typical Source
FLUORIDE	2/6/2024	AVOYELLES WATER COMMISSION	0.3	0.3	ppm	4	4	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
HEXACHLOROCYCLOPENTADIENE	2/6/2024	AVOYELLES WATER COMMISSION	0.077	0.077	ppb	50	50	Discharge from chemical factories

Radionuclides	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
COMBINED RADIUM (-226 & -228)	3/15/2023	0.707	0 - 0.707	pCi/l	5	0	Erosion of natural deposits
GROSS BETA PARTICLE ACTIVITY	3/15/2023	2.11	0 - 2.11	pCi/l	50	0	Decay of natural and man-made deposits.

Lead and Copper	Date	90TH Percentile	Range	Unit	AL	Sites Over AL	Typical Source
COPPER, FREE	2023	0	0 - 0.2	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives

LEAD	2023	0	0 - 1	ppb	15	0	Corrosion of household plumbing systems; Erosion of natural deposits
------	------	---	-------	-----	----	---	--

Disinfection Byproducts	Sample Point	Period	Highest LRAA	Range	Unit	MCL	MCLG	Typical Source
TOTAL HALOACETIC ACIDS (HAA5)	323 COUVILLION ST	2025	14	14	ppb	60	0	By-product of drinking water disinfection
TOTAL HALOACETIC ACIDS (HAA5)	618 MAIN STREET	2025	13	12.8	ppb	60	0	By-product of drinking water disinfection
TTHM	323 COUVILLION ST	2025	39	39.2	ppb	80	0	By-product of drinking water chlorination
TTHM	618 MAIN STREET	2025	37	37	ppb	80	0	By-product of drinking water chlorination

Source Secondary Contaminants	Water System	Collection Date	Highest Value	Range	Unit	SMCL
CHLORIDE	AVOYELLES WATER COMMISSION	2/6/2024	55	55	MG/L	250
HARDNESS, TOTAL (AS CaCO3)	AVOYELLES WATER COMMISSION	2/6/2024	20	20	MG/L	0
MANGANESE	AVOYELLES WATER COMMISSION	3/13/2025	0.01	0.01	MG/L	0.05
PH	AVOYELLES WATER COMMISSION	2/6/2024	8.07	8.07	PH	8.5
POTASSIUM	AVOYELLES WATER COMMISSION	2/6/2024	3.5	3.5	MG/L	0
SODIUM	AVOYELLES WATER COMMISSION	2/6/2024	112.5	112.5	MG/L	0
SULFATE	AVOYELLES WATER COMMISSION	2/6/2024	4	4	MG/L	250

+++++Environmental Protection Agency Required Health Effects Language+++++

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. VILLAGE OF MOREAUVILLE WATER SYSTEM is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of

dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact VILLAGE OF MOREAUVILLE WATER SYSTEM and BERYL HOLMES BUS Phone: 318-985-2338. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

There are no additional required health effects notices.

There are no additional required health effects violation notices.

+++++

Thank you for allowing us to continue providing your family with clean, quality water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers.








We at the VILLAGE OF MOREAUVILLE WATER SYSTEM work around the clock to provide top quality drinking water to every tap. We ask that all our customers help us protect and conserve our water sources, which are the heart of our community, our way of life, and our children's future. Additional information on the water system can be found at www.ldh.la.gov/watergrade. Please call our office if you have questions.

VILLAGE OF MOREAUVILLE WATER SYSTEM

Parish: AVOYELLES

PWSID: LA1009012

2025 Water Grade

 Federal Water Quality	<p>Points deducted for federal violations, which include Treatment Technique and Maximum Contaminant Level Violations, may pose a public health risk over an extended period of time.</p> <p style="text-align: right;">Max of 30 points</p>	<p>-0</p>
 State Water Quality	<p>Points deducted for state violations, which include no water operator, inadequate water disinfection, and boil notices and water outages, may lead to other issues of concern if not resolved.</p> <p style="text-align: right;">Max of 10 points</p>	<p>-0</p>
 Financial Sustainability	<p>Points deducted for lack of financial sustainability which can affect operations and maintenance of the water system. An effective water rate can provide for the repair, maintenance, and future replacement of infrastructure.</p> <p style="text-align: right;">Max of 10 points</p>	<p>-0</p>
 Operations & Maintenance	<p>Points deducted for operation and maintenance deficiencies noted during water system inspections, which may affect the water quality being distributed to consumers.</p> <p style="text-align: right;">Max of 15 points</p>	<p>-0</p>
 Infrastructure	<p>Points deducted for infrastructure deficiencies noted during water system inspections, which may lead to unsafe drinking water and/or water service disruption.</p> <p style="text-align: right;">Max of 20 points</p>	<p>-0</p>
 Customer Satisfaction	<p>Points deducted for customer complaints received by the water system and/or the Louisiana Department of Health, which are confirmed to be a water quality or quantity issue in the water system.</p> <p style="text-align: right;">Max of 10 points</p>	<p>-2</p>
	<p>Points deducted for levels of iron and/or manganese greater than the secondary maximum contaminant levels. These levels do not pose a health risk but may</p>	<p>-0</p>

2025 CCR CERTIFICATION OF DISTRIBUTION FORM

PWS ID: LA1009012

NAME: VILLAGE OF MOREAUVILLE WATER SYSTEM

The Consumer Confidence Report (CCR) must be delivered to your consumers by 06/30/2026 and certification must be submitted to the State no later than 09/30/2026.

The CCR must be distributed with a "good-faith effort" based on the population served by the Community Water System (CWS) as shown:	
Population	Delivery Method
1725	Must mail or otherwise directly deliver one copy of the report to every customer or publish the report in one or more local newspapers serving the area (if publishing in newspaper, the CWS must notify the customers that the report will not be mailed (include in newspaper or in bill))
As an alternative to mailing the CCR, the CWS has the option of choosing an electronic delivery method . On the reverse side of this page, you will find options for electronic delivery that meet the "mail or otherwise directly deliver" requirement of the CCR Rule. If choosing to distribute the report electronically, you must check the option(s) used on the reverse side of this page and complete all required elements. You may also use a combination of the above delivery method and electronic delivery to reach all consumers.	
The below noted community public water system confirms that its 2025 Consumer Confidence Report has been prepared and delivered to its consumers in accordance with the appropriate delivery method based on population served. Furthermore, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the primacy agency as well as fulfilling all CCR requirements of CFR Title 40, Part 141.	
Certified by: Signature: <u>Norris Lemoine</u>	
Printed Name/Job Title: <u>NORRIS Lemoine Jr Director</u>	
Date of CCR Report Delivery: ___/___/___ Type of Delivery: _____	
<input type="checkbox"/> (I have attached a copy of the report and notification provided to consumers)	
Direct URL (Electronic delivery only): _____	

If the CCR is delivered by posting, mail out, or by hand, a copy of the pamphlet or mail out, even if no changes were made, must be attached to the returned certification form. Copies of the report must be kept for three years and made available to the public or the State upon request. Any questions or requests can be addressed to Spencer Hillyard (spencer.hillyard@la.gov/225-342-0272) or Sean Nolan (sean.nolan@la.gov/225-342-7495).

Electronic copies of the reports can be found in the Consumer Confidence Reports section at
<https://ldh.la.gov/bureau-of-engineering-services/CCR>

Mail signed and completed form and final copy of report to:

Attn: Spencer Hillyard, CCR Compliance
 LDH/OPH Engineering Services
 P.O. Box 4489
 Baton Rouge, LA 70821-4489

This page is for certification to the State only and is not part of the report.